

National Load Despatch Centre
Import Capability of Uttar Pradesh for September 2024

Issue Date: -30/08/24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2024 to 30th September 2024	00-24	17300	600	16700	10165	6535		https://www.upslc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde
Limiting Constraints		N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Agra(PG), Lucknow (PG) ICTs						

National Load Despatch Centre
Import Capability of Haryana for September 2024

Issue Date: -30/08/24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2024 to 30th September 2024	00-24	10300	300	10000	5418	4582		https://hvpn.org.in/#/atcttc
Limiting Constraints		N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB)						

National Load Despatch Centre
Import Capability of Rajasthan for September 2024

Issue Date: -30/08/24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2024 to 30th September 2024	00-24	7600	600	7000	5755	1245		https://sldc.rajasathan.gov.in/rrvpn/scheduling/downloads
Limiting Constraints		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs						

National Load Despatch Centre
Import Capability of Delhi for September 2024

Issue Date: -30/08/24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2024 to 30th September 2024	00-24	7300	300	7000	4810	2190		https://www.delhisldc.org/resources/atctcreport.pdf
Limiting Constraints		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

National Load Despatch Centre
Import Capability of Uttarakhand for September 2024

Issue Date: -30/08/24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2024 to 30th September 2024	00-24	1700	100	1600	1402	198		https://uksldc.in/ttc-atc
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

National Load Despatch Centre
Import Capability of HP for September 2024

Issue Date: -30/08/24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2024 to 30th September 2024	00-24	850	100	750	1130	-380		https://hpsldc.com/mrm_category/ttc-atc-report/
Limiting Constraints		High loading of 220kV Hamirpur-Hamirpur D/C. Overloading of 2*200MVA Kunihar transformers						

National Load Despatch Centre
Import Capability of J&K for September 2024

Issue Date: -30/08/24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2024 to 30th September 2024	00-24	2500	100	2400	1977	423		
Limiting Constraints		N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora						

National Load Despatch Centre
Import Capability of Chandigarh for September 2024

Issue Date: -30/08/24

Issue Time: 1600

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2024 to 30th September 2024	00-24	400	20	380	342	38		
Limiting Constraints		N-1 contingency of 220kV Nallagarh-Kishengarh						