

**National Load Despatch Centre**  
**Import Capability of Uttar Pradesh for February 2022**

Issue Date: 01-02-2022

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st February 2022 to 28th February 2022	00-24	13800	600	13200	8420	4780		<a href="https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde">https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Sohawal (PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import Capability of Rajasthan for February 2022**

Issue Date: 01-02-2022

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st February 2022 to 28th February 2022	00-24	6200	300	5900	3400	2500		<a href="https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads">https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Chittorgarh, Jodhpur, Bikaner, Ajmer, Merta and Bhinmal ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import Capability of Haryana for February 2022**

Issue Date: 01-02-2022

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st February 2022 to 28th February 2022	00-24	8500	600	7900	3000	4900		<a href="https://hvpn.org.in/#/atcttc">https://hvpn.org.in/#/atcttc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV ICTs at Deepalpur and Kurukshetra(PG)						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import Capability of Delhi for February 2022**

Issue Date: 01-02-2022

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st February 2022 to 28th February 2022	00-24	6800	300	6500	4150	2350		
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Mundka and Bamnauli ICTs.						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import Capability of HP for February 2022**

Issue Date: 01-02-2022

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st February 2022 to 28th February 2022	00-24	1400	100	1300	1400	-100		<a href="https://hpslhc.com/mrm_category/ttc-atc-report/">https://hpslhc.com/mrm_category/ttc-atc-report/</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Nallagarh ICTs. High loading of 220kV Nallagarh-Upernangal D/C and 220kV Hamirpur-Hamirpur D/C						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

**National Load Despatch Centre**  
**Import Capability of Uttarakhand for February 2022**

Issue Date: 01-02-2022

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)</b>	<b>Margin Available for Short Term Open Access (STOA) (MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st February 2022 to 28th February 2022	00-24	1600	100	1500	1020	480		
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages