

National Load Despatch Centre
Import Capability of Uttar Pradesh for February 2023

Issue Date: - 28.01.2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2023 to 28th February 2023	00-24	15100	600	14500	8420	6080		https://www.upslhc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde
Limiting Constraints		N-1 contingency of 400/220kV Azamgarh, Odra, Mau, Sohawal (PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import Capability of Rajasthan for February
2023

Issue Date: -28.01.2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2023 to 28th February 2023	00-24	7600	600	7000	3400	3600		https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads
Limiting Constraints		N-1 contingency of 400/220kV Chittorgarh, Jodhpur, Bikaner, Ajmer, Merta and Bhinmal ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import Capability of Haryana for February
2023

Issue Date: -28.01.2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2023 to 28th February 2023	00-24	9100	600	8500	3000	5500		https://hvpn.org.in/#/atcttc
Limiting Constraints		N-1 contingency of 400/220kV ICTs at Deepalpur, Panipat(BBMB) and Kurukshetra(PG)						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre Import Capability of Delhi for February 2023

Issue Date: -28.01.2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2023 to 28th February 2023	00-24	7100	300	6800	4150	2650		https://www.delhisldc.org/resources/atcttcreport.pdf
Limiting Constraints		N-1 contingency of 400/220kV Mundka, HarshVihar and Mandola ICTs.						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre Import Capability of HP for February 2023

Issue Date: -28.01.2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2023 to 28th February 2023	00-24	1400	100	1300	1400	0		https://hpslhc.com/mrm_category/ttc-atc-report/
Limiting Constraints		N-1 contingency of 400/220kV Nallagarh ICTs. High loading of 220kV Nallagarh-Upernangal D/C and 220kV Hamirpur-Hamirpur D/C						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import Capability of Uttarakhand for February 2023

Issue Date: -28.01.2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2023 to 28th February 2023	00-24	1700	100	1600	1020	580		http://uksldc.in/transfer-capability
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages