

National Load Despatch Centre
Import of Odisha Transfer Capability for January 2022

Issue Date: 26th December 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2022 to 31st January 2022	00-24	2360	104	2256	2758	-502		Assumption 3040 MW as generation and 5198 MW as load
Limiting Constraints		N-1 contingency of 220 kV Rourkella tarkera d/c						