

National Load Despatch Centre
Import of ODISHA Transfer Capability for August 2021

Issue Date: 26th July 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2021 to 31st August 2021	00-24	2767	90	2677	1000	1677		Assumption 1906 MW as generation and 4500 MW as load
Limiting Constraints		N-1 contingency of 220 kV Bolangir-New Bolangir, Outage of OPGC unit 4, Outage of Sterlite unit 2						