

NATIONAL LOAD DESPATCH CENTRE

URGENT MARKET INFORMATION

Date & Time of Issue: 27-FEB-2012 at 15:30 Hrs

ATC OF NER-ER Corridor FOR FEBRUARY 2012

In view of the nation wide strike called by unions (INTUC, BMS & CITU) the planned shutdown of 400kV Balipara-Bongaigaon II is withdrawn for 28.02.12.

In view of above conditions, the ATC-TTC of NER-ER corridor during the above period shall be as follows:

During this period, **import capability** of NER is revised as follows:

I) Import capability of NER (for 23.02.12)

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
ER→NER	00:00-17:00	500	200	35	265
	23:00-24:00	500	200	35	265
	17:00-23:00	500	200	35	265

The limiting factor in Import Capability of NER is due to following constraints –

- (N-1) contingency of 400kV Balipara-Bongaigaon I
- High loading of 220kV BTPS-Agia S/C

During this period, **export capability** of NER is revised as follows:

I) Export capability of NER (for 23.02.12)

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
NER→ ER	00:00-17:00	570	0	100	470
	23:00-24:00	570	0	100	470
	17:00-23:00	570	0	100	470

The limiting factor in Export Capability of NER is due to following constraints –

- (N-1) contingency of 400kV Balipara-Bongaigaon I
- High loading of 220kV BTPS-Agia S/C.