

**National Load Despatch Centre ,**  
**New Delhi**  
**URGENT MARKET INFORMATION**

Issue Date: 20/07/12

Issue Time: 18:00

ER-SR export TTC/ATC is revised due to shut down of 400 kV Kolaghat-Kharagpur-Baripada S/C on 22-07-12 for checking of Bus differential protection at 400 kV Kharagpur s/s (WBSETCL) by WBSETCL.

<b>Corridor/ Control Area</b>	<b>Time Period (Hours)</b>	<b>TTC- Pre- revised</b>	<b>TTC (revised)</b>	<b>Reliabilit y Margin (RM)</b>	<b>Available Transfer Capability (ATC)</b>	<b>Constraint</b>
<b>ER-SR</b>	<b>1000-1600</b>	<b>1100</b>	<b>800</b>	<b>00</b>	<b>800</b>	<b>400 kV Talcher-Rourkela loading and TSTPP STG-I one Unit</b>