



POWER SYSTEM OPERATION CORPORATION
NATIONAL LOAD DESPATCH CENTRE

B-9, QUTUB INSTITUTIONAL AREA,
KATWARIA SARAI, NEW DELHI- 110016

Message No:- 115/089

Date:- 11/06/2016

From:- Shift Charge Manager, NLDC

To:- SCM

NRLDC	WRLDC	SRLDC	ERLDC	NERLDC
-------	-------	-------	-------	--------

Sub:- Revision of TTC/ATC on account of Tripping/ Revival of power system elements.

For - 11/06/2016

Sr. No.	Corridor	Current (MW)		Revised (MW)		Time Blocks	Reason for Revision
		TTC	ATC	TTC	ATC		
1.	ER-SR	2650	2650	2350	2350	88-96 (11/06/16)	Tripping of
2.	Import of SR	6650	5900	6350	5600	88-96 (11/06/16)	400kV Rengali- Indravati s/c.

SCM, NLDC