

NATIONAL LOAD DESPATCH CENTRE
URGENT MARKET INFORMATION

Date of Issue: 13-MAR-2012

ATC OF NER-ER Corridor FOR 13th March, 2012

Due to restoration of 400kV Balipara-Bongaigaon I at 1302 Hr of 13.03.12 (which was under shutdown w.e.f 0800Hrs to 1600Hrs of 13.03.12), the ATC-TTC of NER-ER corridor is revised as follows:

During this period, **import capability** of NER is revised as follows:

I) Import capability of NER

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
ER→NER	00:00-08:00	450	200	35	215
	08:00-14:00	305	200	35	70
	14:00-17:00	450	200	35	215
	17:00-24:00	450	200	35	215

The limiting factor in Import Capability of NER is due to following constraints –

- (N-1) contingency of 400kV Balipara-Bongaigaon II
- High loading of 220kV BTPS-Agia S/C.

During this period, **export capability** of NER is revised as follows:

I) Export capability of NER

Link	Time period	TTC	LTA	RM	ATC = TTC-LTOA-RM
NER→ER	00:00-08:00	570	0	100	470
	08:00-14:00	170	0	100	70
	14:00-17:00	570	0	100	470
	17:00-24:00	570	0	100	470

The limiting factor in Export Capability of NER is due to following constraints –

- (N-1) contingency of 400kV Balipara-Bongaigaon II
- High loading of 220kV BTPS-Agia S/C.