



POWER SYSTEM OPERATION CORPORATION
NATIONAL LOAD DESPATCH CENTRE

B-9, QUTUB INSTITUTIONAL AREA,
KATWARIA SARAI, NEW DELHI- 110016

Message No:- 115/064

Date: 24/05/16

Time: 09:44

From:- Shift Charge Manager, NLDC

To:- SCM

NRLDC	WRLDC	SRLDC	ERLDC	NERLDC
-------	-------	-------	-------	--------

Sub:- Revision of TTC/ATC on account of Tripping/ Revival of power system elements.

Sr. No.	Corridor	Current (MW)		Revised (MW)		Time Blocks	Reason for Revision
		TTC	ATC	TTC	ATC		
1)	WR-NR	58 6700	6200	5850	5350	43-96	Tripping of 765KV
2)	NR-Import	8400	7600	7300	6500	43-96	Phagi-Bhiwani

For
S/I

SCM, NLDC