



POWER SYSTEM OPERATION CORPORATION
NATIONAL LOAD DESPATCH CENTRE

B-9, QUTUB INSTITUTIONAL AREA,
KATWARIA SARAI, NEW DELHI- 110016

Message No:- 108/11

Date: 12.09.16 Time: 21:05

From:- Shift Charge Manager, NLDC

To:- SCM NRLDC WRLDC SRLDC ERLDC NERLDC

Sub:- Revision of TTC/ATC on account of ~~Tripping~~ Revival of power system elements.

Sr. No.	Corridor	Current (MW)		Revised (MW)		Time Blocks	Reason for Revision
		TTC	ATC	TTC	ATC		
	WB-NR	5800	5300	6400	5900	88-96	400KV M'Garh & Dharaunda I&D Restored.
	NR Import	8500	7700	9450	8650	88-92	
		9200	8400	10200	9400	93-96	

विनाय
12-09-16
SCM, NLDC