

POWER SYSTEM OPERATION CORPORATION

NATIONAL LOAD DESPATCH CENTRE

B-9, QUTUB INSTITUTIONAL AREA,

KATWARIA SARAI, NEW DELHI-110016



Message No:- 106/058

Date: 28/09/2016

Time: 2059

From:- Shift Charge Manager, NLDC

To:- SCM

NRLDC	WRLDC	SRLDC	ERLDC	NERLDC
-------	-------	-------	-------	--------

Sub:- Revision of TTC/ATC on account of Tripping/Revival of power system elements.

Sr. No.	Corridor	CURRENT (MW)	CURRENT (MW)	Revised (MW)	Revised (MW)	Time Blocks	Reason for
		ITC	ATC	TTC	ATC		
01	WR-NR	6600	6100	5600	5100	00-48 at 29/09/16	Shutdown of 765kV Phagi- Bhiwani S/c
02	NR import	10500	9700	8900	8100	00-48 at 29/09/16	

विनीश
SCM, NLDC 28-09-16