

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for April 2017**

Issue Date: 26/12/2016

Issue Time: 19:00 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st April 2017 to 30th April 2017	00-24	5040	400	4640	4025	615	0	Revision-0

<b>Limiting Constraint</b>	(n-1) contingency of 400kV Mywadi - Palakkad D/C
----------------------------	--