

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for August 2015**

Issue Date: 29/06/2015

Issue Time: 1300 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1 <sup>st</sup> to 25 <sup>th</sup>	00:00 Hrs. -24:00 Hrs.	4060	350	3710	2280	1430	825	Revised due to 400kV MTR - TVLM DC , NTPL Unit -1 Commissioning and KKNPP
26 <sup>th</sup> to 28 <sup>th</sup>	00:00 Hrs. -24:00 Hrs.				2435	1275		
29 <sup>th</sup> to 31 <sup>st</sup>	00:00 Hrs. -24:00 Hrs.				2634	1076		

<b>Limiting Constraint</b>	(n-1) contingncy of 400kV Kolar-Hosur D/C
----------------------------	---

**National Load Despatch Centre  
Total Transfer Capability for August 2015**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	26-06-2015	01-08-2015 to 31-08-2015	Revised due to 400kV MTR - TVLM DC , NTPL Unit -1 Commissioning and KKNPP Unit - 1 Outage
1	29-06-2015	01-08-2015 to 31-08-2015	Revised due to 400kV MTR - TVLM DC , NTPL Unit -1 Commissioning and KKNPP Unit - 1 Outage