

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for August 2015

Issue Date: 21/07/2015

Issue Time: 1200 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1 st to 4 th	00:00 Hrs. -24:00 Hrs.	4155	350	3805	2619	1186	95	Revised due to LGBR Changes in 109th OCCM , Revised Unit Outages, NLC2Exp Unit -1 Commissioning , 400kV Karaikudi - Pugalur DC Commissioning and STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
5 th to 25 th	00:00 Hrs. -24:00 Hrs.				2420	1385		
26 th to 28 th	00:00 Hrs. -24:00 Hrs.				2575	1230		
29 th to 31 st	00:00 Hrs. -24:00 Hrs.				2774	1031		

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	--

**National Load Despatch Centre
Total Transfer Capability for August 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	26-06-2015	01-08-2015 to 31-08-2015	Revised due to 400kV MTR - TVLM DC , NTPL Unit -1 Commissioning and KKNPP Unit - 1 Outage
2	21-07-2015	01-08-2015 to 31-08-2015	Revised due to LGBR Changes in 109th OCCM , Revised Unit Outages, NLC2Exp Unit -1 Commissioning , 400kV Karaikudi - Pugalur DC Commissioning and STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.