

**Natioanal Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for August 2015**

Issue Date: 07/08/2015

Issue Time: 1730 hrs

Revision No. 5

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1 <sup>st</sup> to 4 <sup>th</sup>	00:00 Hrs. -24:00 Hrs.	4205	350	3855	2619	1236		Considering the NEW Outages as Decide in 110th OCCM , NCTPS Stage Unit 2 Outage Extension upto 20th August 2015.
5th	00:00 Hrs. -19:00 Hrs.			2420		1435		
	19:00 Hrs. - 24:00 Hrs.	4385		4035	2728	1307		
6th to 8th	00:00 Hrs. -24:00 Hrs.	4385		4035	2728	1307		
9th to 15th	00:00 Hrs. -24:00 Hrs.	4205		3855	2465	1390	50	
16th to 20th	00:00 Hrs. -24:00 Hrs.	4385		4035	2573	1462	230	
21st to 24th	00:00 Hrs. -24:00 Hrs.	4390		4040	2895	1145	235	
25th	00:00 Hrs. -24:00 Hrs.	4390		4040	2696	1344	235	
26 <sup>th</sup> to 27th	00:00 Hrs. -24:00 Hrs.	4155		3805	2575	1230	0	
28th	00:00 Hrs. -24:00 Hrs.	4155		3805	2432	1373	0	
29th	00:00 Hrs. -24:00 Hrs.	4155		3805	2509	1296	0	
30th to 31st	00:00 Hrs. -24:00 Hrs.	4155		3805	2420	1385	0	

<b>Limiting Constraint</b>	<b>(n-1) contingnecy of 400kV Mywadi - Palakkad D/C upto 20th August and from 21th to 31st August 400kV Kolar - Hosur D/C</b>
----------------------------	---

**National Load Despatch Centre  
Total Transfer Capability for August 2015**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	6/26/2015	01-08-2015 to 31-08-2015	Revised due to 400kV MTR - TVLM DC , NTPL Unit -1 Commissioning and KKNPP Unit - 1 Outage
2	7/20/2015	01-08-2015 to 31-08-2015	Revised due to LGBR Changes in 109th OCCM , Revised Unit Outages, NLC2Exp Unit -1 Commissioning , 400kV Karaikudi - Pugalur DC Commissioning and STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
3	7/21/2015	01-08-2015 to 10-08-2015	Due to Outage Extension of NCTPS Stage 2 Unit -2
4	8/5/2015	06-08-2015 to 08-08-2015	Due to Outage Extension of Vallur Unit - 2
5	8/7/2015	11-08-2015 to 20-08-2015	Considering the NEW Outages as Decide in 110th OCCM , NCTPS Stage Unit 2 Outage Extension upto 20th August 2015.