

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for Aug 2016**

Issue Date: 28/04/2016

Issue Time: 17:00 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st August 2016 to 31st August 2016	00-24	6480	400	6080	3463	2617	0	Revision-0

<b>Limiting Constraint</b>	<b>(n-1) contingnecy of 400kV Hiriyr - Nelamangala D/C</b>
----------------------------	--

**National Load Despatch Centre  
Transfer Capability between S1-S2 for Aug 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	4/28/2016	01-08-2016 to 31-08-2016	Revision-0