

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for Aug 2016**

Issue Date: 04/08/2016

Issue Time: 17:45 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2016 to 4th August 2016	0000-2400	6106	404	5702	3474	2228		
5th August 2016	0000-0530				3474	2228		
5th August 2016	0530-2400	5649		5245	3474	1771	-457	
6th August 2016	0000-2400				3474	1771		
7th August 2016 to 21st August 2016	0000-2400	6106		5702	3474	2228		
22nd August 2016 to 31st August 2016					3671	2031		

Due to SD of 400kV Mettur-Tiruvalam-1&2 from 05-08-2016 to 06-08-2016

<b>Limiting Constraint</b>	<b>(n-1) contingnecy of 400kV Hiriyr - Nelamangala D/C</b>
----------------------------	--

**National Load Despatch Centre  
Transfer Capability between S1-S2 for Aug 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	26-04-2016	01-08-2016 to 31-08-2016	Revision-0
1	20-07-2016	01-08-2016 to 31-08-2016	Considering Latest LGBR & ISGS Outage Plan as per 121st OCCM
2	04-08-2016	05-08-2016 to 06-08-2016	Due to SD of 400kV Mettur-Tiruvalam-1&2 from 05-08-2016 to 06-08-2016