

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for December 2015

Issue Date: 28/08/2015

Issue Time: 1400 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 4th	00:00 Hrs. -24:00 Hrs.	3495	320	3175	3490	0		
5th to 6th	00:00 Hrs. -24:00 Hrs.							
7th to 11th	00:00 Hrs. -24:00 Hrs.							
12th to 31st	00:00 Hrs. -24:00 Hrs.							

Existing LTA/MTOA plus notional LTA/MTOA granted by CTU as per CERC orders dated 16th Feb 2015 and 3rd Jul 2015 in petition nos 92/MP/2014 and 92/MP/2015. Notional LTA/MTOA will be operationalized based on margins available from time to time.

Limiting Constraint	(n-1) contingnecy of 400kV Udumalpet - Palakkad D/C
----------------------------	--

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for December 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision