

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for December 2015

Issue Date: 02/12/2015

Issue Time: 1000 hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st	00:00 Hrs. -24:00 Hrs.	7091	350	6741	3836	2905		
2nd	00:00 Hrs. -10:00 Hrs.	7091		6741	3836	2905		
	10:00 Hrs. -24:00 Hrs.	4200		3850	3836	14	-2891	Due to Severe Demand Crash in Chennai Area , Tripping of 400kV Kalivindhapattu - Pugalur DC , 400kV SVCTM - PONDY S/C flow around 860 MW , Less Generation at NCTPS Stage 2 ,and Nil IL&FS and Coastal Generation , Neyvelli Also less generation due WET Coal
	3rd to 4th	00:00 Hrs. -24:00 Hrs.		7091	6741	3836	2905	
5th to 11th	00:00 Hrs. -24:00 Hrs.	3887				2854		
12th to 14th	00:00 Hrs. -24:00 Hrs.	3808				2933		
15th to 31th	00:00 Hrs. -24:00 Hrs.	3731				3010		

Limiting Constraint	(n-1) contingncy of 400kV Hosur- Salem D/C
----------------------------	---

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for December 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	8/25/2015	01-12-2015 to 31-12-2015	Revision-0
1	10/5/2015	01-12-2015 to 31-12-2015	Operationalization of 530 MW LTA
2	11/20/2015	01-12-2015 to 31-12-2015	Considering Latest LGBR & ISGS Outage Plan as per 113 OCCM , Considering Ambient Temperature of 31 deg for 400kV Hsour - Salem DC
3	12/2/2015	12/2/2015	Due to Severe Demand Crash in Chennai Area , Triiping of 400kV Kalivindhapattu - Pugalur DC , 400kV SVCTM - PONDY S/C flow around 860 MW , Less Generation at NCTPS Stage 2 ,and Nil IL&FS and Coastal Generation , Neyvelli Also less generation due WET Coal