

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for December 2015**

Issue Date: 15/12/2015

Issue Time: 1700 hrs

Revision No. 7

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
1st	00:00 Hrs. -24:00 Hrs.	7091	350	6741	3836	2905				
2nd	10:00 Hrs. -24:00 Hrs.	4200		3850	3836	14				
3rd	00:00 Hrs. -24:00 Hrs.									
4th	00:00 Hrs. -13:00 Hrs.	5180		4830	3887	943				
	13:00 Hrs. -24:00 Hrs.									
5th to 7th	00:00 Hrs. -24:00 Hrs.	7091				3887	2854			
8th to 9th	00:00 Hrs. -24:00 Hrs.					3808	2933			
10th to 11th	00:00 Hrs. -24:00 Hrs.						3731	3010		
12th to 14th	00:00 Hrs. -24:00 Hrs.									
15th	00:00 Hrs. -24:00 Hrs.				6741					
16th to 31th	00:00 Hrs. -24:00 Hrs.					4184	2557		Due to Operationalisation of LTA of 700 MW to TN & 14.5 MW to KSEB	

<b>Limiting Constraint</b>	(n-1) contingency of 400kV Hosur- Salem D/C
----------------------------	---

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for December 2015**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	8/25/2015	01-12-2015 to 31-12-2015	Revision-0
1	10/5/2015	01-12-2015 to 31-12-2015	Operationalization of 530 MW LTA
2	11/20/2015	01-12-2015 to 31-12-2015	Considering Latest LGBR & ISGS Outage Plan as per 113 OCCM , Considering Ambient Temperature of 31 deg for 400kV Hsour - Salem DC
3	12/2/2015	12/2/2015	Due to Severe Demand Crash in Chennai Area , Triiping of 400kV Kalivindhapattu - Pugalur DC , 400kV SVCTM - PONDY S/C flow around 860 MW , Less Generation at NCTPS Stage 2 ,and Nil IL&FS and Coastal Generation , Neyvelli Also less generation due WET Coal
4	12/3/2015	12/4/2015	Due to Severe Demand Crash in Chennai Area , Triiping of 400kV Kalivindhapattu - Pugalur DC , 400kV SVCTM - PONDY S/C flow around 860 MW , Less Generation at NCTPS Stage 2 ,and Nil IL&FS and Coastal Generation , Neyvelli Also less generation due WET Coal
5	12/3/2015	04-12-2015 to 07-12-2015	Due to Severe Demand Crash in Chennai Area , Triiping of 400kV Kalivindhapattu - Pugalur DC , 400kV SVCTM - PONDY S/C flow around 860 MW , Less Generation at NCTPS Stage 2 ,and Nil IL&FS and Coastal Generation , Neyvelli Also less generation due WET Coal
6	12/4/2015	04-12-2015 to 09-12-2015	Due to restoration of 400kV Kalivindhapattu - Pugalur D/C
7	12/15/2015	16-12-2015 to 31-12-2015	Due to Operationalisation of LTA of 700 MW to TN & 14.5 MW to KSEB