

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for December 2015

Issue Date: 29/12/2015

Issue Time: 1000 hrs

Revision No. 8

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments				
1st	00:00 Hrs. -24:00 Hrs.	7091	350	6741	3836	2905						
2nd	10:00 Hrs. -24:00 Hrs.	4200		3850	3836	14						
3rd	00:00 Hrs. -24:00 Hrs.											
4th	00:00 Hrs. -13:00 Hrs.	5180		350	4830	3887	943					
	13:00 Hrs. -24:00 Hrs.											
5th to 7th	00:00 Hrs. -24:00 Hrs.	7091			6741	3887	2854					
8th to 9th	00:00 Hrs. -24:00 Hrs.					3808	2933					
10th to 11th	00:00 Hrs. -24:00 Hrs.	7091			6741	3731	3010					
12th to 14th	00:00 Hrs. -24:00 Hrs.					4184	2557					
15th	00:00 Hrs. -24:00 Hrs.											
16th to 28th	00:00 Hrs. -24:00 Hrs.	6455			6105	4184	1921				Due to SD of 400kV SVCTM - Pandy S/C line	
29th	10:15 Hrs. -18:00 Hrs.	7091			6741	6741	4184			2557		
	00:00 Hrs. -10:15 Hrs. & 18:00 Hrs. -24:00 Hrs.											
30th to 31th	00:00 Hrs. -24:00 Hrs.	7091			6741	4184	2557					

Limiting Constraint	(n-1) contingency of 400kV Hosur- Salem D/C
----------------------------	--

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for December 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	8/25/2015	01-12-2015 to 31-12-2015	Revision-0
1	10/5/2015	01-12-2015 to 31-12-2015	Operationalization of 530 MW LTA
2	11/20/2015	01-12-2015 to 31-12-2015	Considering Latest LGBR & ISGS Outage Plan as per 113 OCCM , Considering Ambient Temperature of 31 deg for 400kV Hsour - Salem DC
3	12/2/2015	12/2/2015	Due to Severe Demand Crash in Chennai Area , Triiping of 400kV Kalivindhapattu - Pugalur DC , 400kV SVCTM - PONDY S/C flow around 860 MW , Less Generation at NCTPS Stage 2 ,and Nil IL&FS and Coastal Generation , Neyvelli Also less generation due WET Coal
4	12/3/2015	12/4/2015	Due to Severe Demand Crash in Chennai Area , Triiping of 400kV Kalivindhapattu - Pugalur DC , 400kV SVCTM - PONDY S/C flow around 860 MW , Less Generation at NCTPS Stage 2 ,and Nil IL&FS and Coastal Generation , Neyvelli Also less generation due WET Coal
5	12/3/2015	04-12-2015 to 07-12-2015	Due to Severe Demand Crash in Chennai Area , Triiping of 400kV Kalivindhapattu - Pugalur DC , 400kV SVCTM - PONDY S/C flow around 860 MW , Less Generation at NCTPS Stage 2 ,and Nil IL&FS and Coastal Generation , Neyvelli Also less generation due WET Coal
6	12/4/2015	04-12-2015 to 09-12-2015	Due to restoration of 400kV Kalivindhapattu - Pugalur D/C
7	12/15/2015	16-12-2015 to 31-12-2015	Due to Operationalisation of LTA of 700 MW to TN & 14.5 MW to KSEB
8	12/29/2015	12/29/2015	Due to SD of 400kV SVCTM - Pondy S/C line