

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for December 2016

Issue Date: 29/11/2016

Issue Time: 18:00 hrs

Revision No. 1

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---|--------------------------|---------------------------------|--------------------|-------------------------------------|--|--|-------------------------------------|------------|
| 1st December 2016 to 4th December 2016 | 00-24 | 5426 | 374 | 5052 | 4042 | 1010 | -1906 | Revision-1 |
| 5th December 2016 to 30th December 2016 | | | | | 3964 | 1088 | | |
| 31st December 2016 | | | | | 3874 | 1178 | | |

| | |
|----------------------------|--|
| Limiting Constraint | (n-1) contingency of 400kV Udumalpet - Palakkad D/C |
|----------------------------|--|