

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for February 2017

Issue Date: 26/10/2016

Issue Time: 19:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st February 2017 to 28th February 2017	00-24	5772	376	5396	3916	1480	0	Revision-0

Limiting Constraint	(n-1) contingency of 400kV Mywadi - Palakkad D/C
----------------------------	---