

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for January 2016**

Issue Date: 17/12/2015

Issue Time: 1700 hrs

Revision No. 2

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st January 2015 to 31st January 2015	00:00 Hrs - 24:00 Hrs	6350	370	5980	4110	1870	2555	Considering Latest LGBR & ISGS Outage Plan as per 114th OCCM , Considering Ambient Temperature of 33 deg for 400kV Udumalpet - Palakkad DC

<b>Limiting Constraint</b>	<b>(n-1) contingency of 400kV Udumalpet - Palakkad D/C</b>
----------------------------	--

**National Load Despatch Centre  
Transfer Capability between S1-S2 for January 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	9/26/2015	01-01-2016 to 31-01-2016	Revision-0
1	10/5/2015	01-01-2016 to 31-01-2016	Operationalization of 530 MW LTA
2	12/17/2015	01-01-2016 to 31-01-2016	Considering Latest LGBR & ISGS Outage Plan as per 114th OCCM , Considering Ambient Temperature of 33 deg for 400kV Udumalpet - Palakkad DC