

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for January 2016**

Issue Date: 11/01/2016

Issue Time: 1700 hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st January 2016 to 10th January 2016	00:00 Hrs - 24:00 Hrs	6350	370	5980	4110	1870		
11th January 2016	00:00 Hrs - 24:00 Hrs	5380		5010		900	-970	Due to HVDC Talcher - Kolar Pole Shut-Down*
12th January 2016 to 13th January 2016	00:00 Hrs - 24:00 Hrs							
14th January 2016 to 31st January 2016	00:00 Hrs - 24:00 Hrs	6350		5980		1870		

<b>Limiting Constraint</b>	<b>(n-1) contingnecy of 400kV Udumalpet - Palakkad D/C</b>
	<b>*(n-1) contingnecy of 400kV Gooty - Somnahalli S/C on 400kV Gooty - Nelamangala S/C</b>

**National Load Despatch Centre  
Transfer Capability between S1-S2 for January 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	9/26/2015	01-01-2016 to 31-01-2016	Revision-0
1	10/5/2015	01-01-2016 to 31-01-2016	Operationalization of 530 MW LTA
2	12/17/2015	01-01-2016 to 31-01-2016	Considering Latest LGBR & ISGS Outage Plan as per 114th OCCM , Considering Ambient Temperature of 33 deg for 400kV Udumalpet - Palakkad DC
3	1/11/2016	11-01-2016 to 13-01-2016	Due to HVDC Talcher - Kolar Pole Shut-Down