

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for June 2015

Issue Date: 23/06/2015

Issue Time: 1145 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July to 2nd July	00-24	4460	330	4130	2550	1580	1315	Revised due to LGBR Changes by constituents, Unit Outage Finalised in 108th OCC Meeting and 400kV Tiruvalam-Mettur DC line NTPL Unit -1 commisioning
3rd July to 26th July	00-24	4460	330	4130	2318	1812	1315	
27th July	00-24	4460	330	4130	2407	1723	1315	
28th July- 30th July	00-24	4460	330	4130	2487	1643	1315	
31st July	00-25	4460	330	4130	2398	1732	1615	

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	---

**National Load Despatch Centre
Total Transfer Capability for May 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	22-06-2015	01-07-2015 to 31-07-2015	Revised due to LGBR Changes by constituents & Unit Outage Finalised in 108th OCC Meeting and 400kV Tiruvalam-Mettur line-DC, NTPL UNIT-1 commisioning