

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for June 2015

Issue Date: 30/06/2015

Issue Time: 1215 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July	00-24	4700	330	4370	2550	1820	240	Revised due to NCTPS Stage 2 Unit -2 Outage and Mettur Stage -3 Unit - 1 in -service
2nd July	00 - 08 & 19-24	4700	330	4370	2550	1820	240	
	08-19	4540	330	4210	2550	1660	80	Due to 400kV Kalivindhapattu Pugalur -1 SD
3rd July to 20th July	00-24	4700	330	4370	2318	2052	240	Revised due to NCTPS Stage 2 Unit -2 Outage and Mettur Stage -3 in -service
21st July to 26th July	00-24	4410	330	4080	2318	1762	-50	Due to Mettur Stage 3 Unit -1 Revival
27th July	00-24	4410	330	4080	2407	1673	-50	
28th July- 30th July	00-24	4410	330	4080	2487	1593	-50	
31st July	00-25	4410	330	4080	2398	1682	-50	

Limiting Constraint	(n-1) contingnecy of 400kV Kolar-Hosur D/C
----------------------------	---

**National Load Despatch Centre
Total Transfer Capability for May 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	6/22/2015	01-07-2015 to 31-07-2015	Revised due to LGBR Changes by constituents & Unit Outage Finalised in 108th OCC Meeting and 400kV Tiruvalam-Mettur line-DC, NTPL UNIT-1 commisioning
2	6/30/2015	01-07-2015 to 31-07-2015	Due to Revival of Mettur - Stage 3 Unit -1 and NCTPS Stage 2 Unit -2 Outage & on 2nd June due to 400kV kalivindhapattu - Pugalur -1 SD