

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for July 2015

Issue Date: 03/07/2015

Issue Time: 1300 hrs

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July	00-24	4700	330	4370	2550	1820		
2nd July	00 - 08 & 19-24	4700	330	4370	2550	1820		
	08-19	4700	330	4370	2550	1820		
3rd July	00-24	4700	330	4370	2318	2052		
4th July to 20th July	00-24	4700	330	4370	2550	1820		Revision in LTA Due to TALST2 Unit - 3 Outage Deferment.
21st July to 26th July	00-24	4410	330	4080	2550	1530		
27th July	00-24	4410	330	4080	2639	1441		
28th July- 30th July	00-24	4410	330	4080	2719	1361		
31st July	00-25	4410	330	4080	2629	1451		

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	--

**National Load Despatch Centre
Total Transfer Capability for July 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	22-06-2015	01-07-2015 to 31-07-2015	Revised due to LGBR Changes by constituents & Unit Outage Finalised in 108th OCC Meeting and 400kV Tiruvalam-Mettur line-DC, NTPL UNIT-1 commisioning
2	30-06-2015	01-07-2015 to 31-07-2015	Due to Revival of Mettur - Stage 3 Unit -1 and NCTPS Stage 2 Unit -2 Outage & on 2nd June due to 400kV kalivindhapattu - Pugalur -1 SD
3	01-07-2015	02-07-2015	Due to Defferment of 400kV Kalivindhapattu - Pugalur - 1 SD by PGCIL
4	03-07-2015	03-07-2015 to 31-07-2015	Due to TALST2 Unit - 3 Outage Deferment.