

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for July 2016**

Issue Date: 08/07/2016

Issue Time: 12:00 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st July 2016 to 7th July 2016	00-24	6494	393	6102	3907	2195			
8th July 2016	00-1130	6494		6102	3907	2195			
8th July 2016	1130-24	6055		5663	3907	1756			
9th July 2016	00-24	6055		5663	3907	1756	-439	Due to shutdown of 400kV MTPS-Tiruvalam D/C	
10th July 2016 to 14th July 2016	00-24	6494				3676	2426		
15th July 2016						3889	2213		
16th July 2016 to 29th July 2016						6102	3799	2303	
30th July 2016 to 31st July 2016							3586	2516	

<b>Limiting Constraint</b>	<b>(n-1) contingency of 400kV Hiriyur-Nelamangala D/C</b>
----------------------------	---

**National Load Despatch Centre  
Transfer Capability between S1-S2 for July 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	26-03-16	01-07-2016 to 31-07-2016	Revision-0
1	17/06/2016	01-07-2016 to 31-07-2016	Considering Latest LGBR & ISGS Outage Plan as per 120th OCCM
2	08-07-16	08-07-2016 to 09-07-2016	Due to shutdown of 400kV MTPS-Tiruvalam D/C