

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for July 2016**

Issue Date: 17/06/2016

Issue Time: 1745 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 16 to 9th July 16	00-24	6494	393	6101	3907	2194	-111	Considering Latest LGBR & ISGS Outage Plan as per 120th OCC Meeting.
10th July 16 to 14th July 16	00-24	6494	393	6101	3676	2425	-111	
15th July 16	00-24	6494	393	6101	3889	2212	-111	
16th July 16 to 29th July 16	00-24	6494	393	6101	3799	2302	-111	
30th July 16 to 31st July 16	00-24	6494	393	6101	3586	2515	-111	

<b>Limiting Constraint</b>	<b>(n-1) contingnecy of 400kV Hiriur – Nelamangala D/C</b>
----------------------------	--

**National Load Despatch Centre  
Transfer Capability between S1-S2 for July 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	26/3/2016	01-07-2016 to 31-07-2016	Revision-0
1	17/6/2016	Whole Month	Considering Latest LGBR & ISGS Outage Plan as per 120th OCC Meeting.