

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for June 2015

Issue Date: 04/06/2015

Issue Time: 1300 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2015 to 3rd June 2015	00-24	3400	325	3075	2729	346	790	
4th June 2015	00:00 - 10:30	3400	325	3075	2729	346	790	
	10:30 -24:00	3965	325	3640	2838	802	565	Due to Vallur Unit 2 and Unit 3 Outage
5th June 2015	00:00 - 24:00	3685	325	3360	2946	414	285	Due to Vallur Unit 3 Outage
6th June 2015 to 14th June 2015	00-24	3400	325	3075	2497	578	490	
15th June 2015 to 25th June 2015	00-24	3400	325	3075	2419	656	490	
26th June 2015 to 30th June 2015	00-24	3685	325	3360	2526	834	775	

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	--

**National Load Despatch Centre
Total Transfer Capability for May 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	22/05/2015	01-06-2015 to 30-06-2015	Revised due to LGBR Changes by constituents & Unit Outage Finalised in 107th OCC Meeting and 400kV Tiruvalam-Mettur line-1 commisioning
2	04/06/2015	04/06/2015	Due to Vallur Unit 2 and Unit - 3 Outage
		05/06/2015	Due to Vallur Unit 3 Outage