

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for June 2016

Issue Date: 24/05/2016

Issue Time: 12:00 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2016 to 5th June 2016	00-24	6730	400	6330	4082	2248	548	Considering Latest LGBR & ISGS Outage Plan as per 119th OCCM
6st June 2016 to 15th June 2016	00-24				3889	2441		
15st June 2016 to 30th June 2016	00-24				3661	2669		

Limiting Constraint	(n-1) contingency of 400kV Hiriyur-Neelamangala D/C
----------------------------	--

**National Load Despatch Centre
Transfer Capability between S1-S2 for June 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	26/02/2016	01-06-2016 to 30-06-2016	Revision-0
1	24/05/2016	01-06-2016 to 30-06-2016	Considering Latest LGBR & ISGS Outage Plan as per 119th OCCM