

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for March 2016

Issue Date: 25/02/2016

Issue Time: 12:00 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2015 to 31st March 2015	00-24	5797	370	5427	3562	1865	33	Considering Latest LGBR & ISGS Outage Plan as per 116th OCCM , Considering Ambient Temperature of 38 deg for 400kV Udumalpet - Palakkad DC

Limiting Constraint	(n-1) contingncy of 400kV Udumalpet - Palakkad D/C
----------------------------	---

National Load Despatch Centre
Transfer Capability between S1-S2 for March 2016

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	11/25/2015	01-03-2016 to 31-03-2016	Revision-0
1	12/15/2015	01-03-2016 to 31-03-2016	Due to Operationalisation of LTA of 700 MW to TN & 14.5 MW to KSEB
2	2/19/2016	01-03-2016 to 31-03-2017	Considering Latest LGBR & ISGS Outage Plan as per 116th OCCM , Considering Ambient Temperature of 38 deg for 400kV Udumalpet - Palakkad DC