

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for May 2015**

Issue Date: 28/05/2015

Issue Time: 1305 hrs

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2015	00-24	3220	320	2900	2583	317		
2nd May 2015	00-12	3220	320	2900	2583	317		
	12'-24	3220	320	2900	2583	317		
3rd May 2015	00-24	3220	320	2900	2583	317		
4th May 2015	00-21:45	2920	320	2600	2474	126		
	21:45-24	3265		2945	2474	471		
5th May 2015	00-24	3265	320	2945	2474	471		
6th May 2015	00-19	3265	320	2945	2474	471		
	19-24	3265		2945	2474	471		
7th May 2015	00-08	3265	320	2945	2474	471		
	12-24'	2920	320	2600	2474	126		
8th May 2015	00-24	2920	320	2600	2474	126		
9th May 2015	00-20	2920	320	2600	2474	126		
	20-24	2750	320	2430	2729	0		
10th May 2015	00-13	2750	320	2430	2729	0		
	13-15	3095		2775	2729	46		
	15-24	2750		2430	2729	0		
11th May 2015	00-06	2750	320	2430	2729	0		
	06-19'	2750	320	2430	2729	0		
	19-24'	3045	320	2725	2838	0		
12th May 2015	00-11145	3045	320	2725	2838	0		
	1145-24	3330		3010	2946	64		
13th May 2015	00-06	3330	320	3010	2946	64		
	06-09'	3045		2725	2838	0		
	09-10'	2715		2715	2838	0		
	10-13'	3045		2725	2946	0		
	13-1615'	2715		2395	2838	0		
	1615-19'	3045		2725	2946	0		
	19-24'	3330		3010	2946	64		
14th May 2015	00-06	3880	320	3560	2946	614		
	06-09'	3800		3480	2583	897		
	09-15'	3465		3145	2583	562		
	15-19	3710		3390	2768	622		
	19-24'	4015		3695	2768	927		
15th May 2015	00-09	4015	320	3695	2768	927		
	09-19'	3710		3390	2768	622		
	19-2030	4015		3695	2768	927		
	2030-24'	4075		3755	2659	1096		
16th May 2015	00-24'	4075	320	3755	2659	1096		

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for May 2015**

Issue Date: 28/05/2015

Issue Time: 1305 hrs

Revision No. 4

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
17th May 2015	00-12	4075	320	3755	2659	1096		
	12-24'	3790	320	3470	2551	919		
18th May 2015	00-06	3790	320	3470	2551	919		
	06-0830'	3455	320	3135	2551	584		
19th May 2015	0830-24'	3790	320	3470	2551	919		
	00-15	3790	320	3470	2551	919		
	15-18'	3455	320	3135	2551	584		
20th May 2015	18-24'	3790	320	3470	2551	919		
	00-0830	3790	320	3470	2551	919		
21st May 2015 to 31st May 2015	0830 - 2400	3455	320	3135	2551	584		
	00-24	3455	320	3135	2551	584		
26th May 2015	00:00 - 11:30	3455	320	3135	2551	584		
	11:30 -24:00	3710	320	3390	2659	731		
27th May 2015	00:00 - 24:00	3710	320	3390	2659	731		
28th May 2015	00:00 - 07:15 Hrs.	3710	320	3390	2659	731		
	07:15 - 13:15 Hrs	2730	320	2410	2659	-249		
	13:15 - 24:00 Hrs.	3710	320	3390	2659	731	980	Revised Due to Revival of 400kV Kolar - Hosur - 2
29th May 2015 to 31st May 2015	00-24	3455	320	3135	2551	584		

<b>Limiting Constraint</b>	<b>(N-1) contingency of 400kV Kolar -Hosur D/C</b>
----------------------------	--

**National Load Despatch Centre  
Total Transfer Capability for May 2015**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	20-05-2015	20-05-2015 to 20-05-2015	Revised Due to NCTPS Stage 2 Unit - 2 Revival
2	26-05-2015	26-05-2015 to 28-05-2015	Revised Due to Vallur TPS U-1 Outage
3	28-05-2015	28-05-2015	Revised Due to tripping of 400kV Kolar - Hosur - 2
4	28-05-2015	28-05-2015	Revised Due to revival of 400kV Kolar - Hosur - 2