

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for May 2016

Issue Date: 28/01/2016

Issue Time: 1900 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2016 to 31st May 2016	00:00 Hrs - 24:00 Hrs	5808	370	5438	4213	1225		Revision - 0

Limiting Constraint	(n-1) contingnecy of 400kV Udumalpet - Palakkad D/C
----------------------------	--

**National Load Despatch Centre
Transfer Capability between S1-S2 for May 2016**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	1/28/2016	01-05-2016 to 31-05-2016	Revision-0