

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for November 2015

Issue Date: 31/10/2015

Issue Time: 1400 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 2nd	00:00 Hrs. -24:00 Hrs.	5990	350	5640	3280	2360	1700	Commissioning of 400kV Mysore - Kozhikode D/C
3rd to 4th	00:00 Hrs. -24:00 Hrs.				3489	2151	1700	
5th to 11th	00:00 Hrs. -24:00 Hrs.				3489	2151	1700	
12th to 14th	00:00 Hrs. -24:00 Hrs.				3409	2231	1700	
15th to 30th	00:00 Hrs. -24:00 Hrs.				3333	2307	1700	

Limiting Constraint	(n-1) contingency of 400kV Hosur - Salem D/C
----------------------------	--

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for November 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	25-07-2015	01-11-2015 to 30-11-2015	Revision-0
1	05-10-2015	01-11-2015 to 30-11-2015	Operationalization of 530 MW LTA
2	31-10-2015	01-11-2015 to 30-11-2015	Commissioning of 400kV Mysore - Kozhikode D/C