

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for October 2015**

Issue Date: 21/07/2015

Issue Time: 1200 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 2nd	00:00 Hrs. -24:00 Hrs.	4040	320	3720	2696	1024	0	STOA Margin revised considering CERC order dated 03-07-2015 in petition No-92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
3rd to 10th	00:00 Hrs. -24:00 Hrs.				2773	947		
11th to 14th	00:00 Hrs. -24:00 Hrs.	3775	3455	2863	592			
15th to 21st	00:00 Hrs. -24:00 Hrs.			2707	748			
22nd	00:00 Hrs. -24:00 Hrs.			2787	668			
23rd	00:00 Hrs. -24:00 Hrs.			2876	579			
24th to 31st	00:00 Hrs. -24:00 Hrs.				2667	788		

<b>Limiting Constraint</b>	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	--

**National Load Despatch Centre  
Total Transfer Capability for October 2015**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	25-06-2015	01-10-2015 to 31-10-2015	Revision-0
1	21-07-2015	01-10-2015 to 31-10-2015	Revised due to LGBR Changes in 109th OCCM , NLC2Exp Unit -1 Commissioning , 400kV Karaikudi - Pugalur DC Commissioning and STOA Margin revised considering CERC order dated 03-07-2015 in petition No-92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.