

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for October 2015

Issue Date: 18/09/2015

Issue Time: 1300 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 2nd	00:00 Hrs. -24:00 Hrs.	4185	330	3855	2393	1462	145	Due to LGBR and ISGS Unit outage Plan changes given in 11th OCC meeting
3rd	00:00 Hrs. -24:00 Hrs.	4185		3855	2470	1385	145	
4th to 5th	00:00 Hrs. -24:00 Hrs.	4185		3855	2669	1186	145	
6th to 10th	00:00 Hrs. -24:00 Hrs.	4185		3855	2580	1275	145	
11th to 14th	00:00 Hrs. -24:00 Hrs.	3910		3580	2471	1109	135	
15th to 19th	00:00 Hrs. -24:00 Hrs.	3910		3580	2522	1058	135	
20th to 22nd	00:00 Hrs. -24:00 Hrs.	3910		3580	2445	1135	135	
23rd to 31st	00:00 Hrs. -24:00 Hrs.	3910		3580	2534	1046	135	

Limiting Constraint	(n-1) contingnecy of 400kV Kolar-Hosur D/C
----------------------------	--

**National Load Despatch Centre
Total Transfer Capability for October 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	25/6/2015	01-10-2015 to 31-10-2015	Revision-0
1	20/7/2015	01-10-2015 to 31-10-2015	Revised due to LGBR Changes in 109th OCCM , NLC2Exp Unit -1 Commissioning , 400kV Karaikudi - Pugalur DC Commissioning and STOA Margin revised considering CERC order dated 03-07-2015 in petition No-92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
1	18/9/2015	01-10-2015 to 31-10-2015	Due to LGBR and ISGS Unit outage Plan changes given in 111th OCC meeting