

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for October 2015

Issue Date: 28/09/2015

Issue Time: 1700 hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 2nd	00:00 Hrs. -24:00 Hrs.	4670	330	4340	2393	1947	485	Considering the Conductor Temperature of 400kV Kolar - Hosur DC @ 85 Deg as given by PGCIL
3rd	00:00 Hrs. -24:00 Hrs.	4670		4340	2470	1870	485	
4th to 5th	00:00 Hrs. -24:00 Hrs.	4670		4340	2669	1671	485	
6th to 10th	00:00 Hrs. -24:00 Hrs.	4670		4340	2580	1760	485	
11th to 14th	00:00 Hrs. -24:00 Hrs.	4460		4130	2471	1659	550	
15th to 19th	00:00 Hrs. -24:00 Hrs.	4460		4130	2522	1608	550	
20th to 22nd	00:00 Hrs. -24:00 Hrs.	4460		4130	2445	1685	550	
23rd to 31st	00:00 Hrs. -24:00 Hrs.	4460		4130	2534	1596	550	

Limiting Constraint	(n-1) contingency of 400kV Mywadi - Palakkad D/C
----------------------------	--

**National Load Despatch Centre
Total Transfer Capability for October 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	6/25/2015	01-10-2015 to 31-10-2015	Revision-0
1	7/20/2015	01-10-2015 to 31-10-2015	Revised due to LGBR Changes in 109th OCCM , NLC2Exp Unit -1 Commissioning , 400kV Karaikudi - Pugalur DC Commissioning and STOA Margin revised considering CERC order dated 03-07-2015 in petition No-92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
2	9/18/2015	01-10-2015 to 31-10-2015	Due to LGBR and ISGS Unit outage Plan changes given in 111th OCC meeting
3	9/28/2015	01-10-2015 to 31-10-2015	Considering the Conductor Temperature of 400kV Kolar - Hosur DC @ 85 Deg as given by PGCIL