Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1-S2 for October 2015

Issue Date: 09/10/2015 Issue Time: 2359 hrs Revision No. 5

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st to 2nd	00:00 Hrs24:00 Hrs.	4670		4340	2393	1947		
3rd	00:00 Hrs24:00 Hrs.	4670		4340	2470	1870		
4th to 5th	00:00 Hrs24:00 Hrs.	4670		4340	2669	1671		
6th to 10th	00:00 Hrs24:00 Hrs.	4670		4340	3110	1230		
11th to 12th	00:00 Hrs24:00 Hrs.	4670	330	4340	3110	1230	210	Vallur Unit -1 Outage Extension .
13th to 14th	00:00 Hrs24:00 Hrs.	4460		4130	3001	1129		
15th to 19th	00:00 Hrs24:00 Hrs.	4460		4130	3052	1078		
20th to 22nd	00:00 Hrs24:00 Hrs.	4460		4130	2975	1155		
23rd to 31st	00:00 Hrs24:00 Hrs.	4460		4130	3064	1066		

Limiting Constraint	(n-1) contingnecy of 400kV Mywadi - Palakkad D/C
------------------------	--

National Load Despatch Centre Total Transfer Capability for October 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision		
0	25-06-2015	01-10-2015 to 31-10-2015	Revision-0		
1	20-07-2015	01-10-2015 to 31-10-2015	Revised due to LGBR Changes in 109th OCCM , NLC2Exp Unit -1 Commissioning , 400kV Karaikudi - Pugalur DC Commissioning and STOA Margin revised considering CERC order dated 03-07-2015 in petition No- 92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.		
2	18-09-2015	01-10-2015 to 31-10-2015	Due to LGBR and ISGS Unit outage Plan changes given in 111th OCC meeting		
3	28-09-2015	01-10-2015 to 31-10-2015	Considering the Conductur Temperature of 400kV Kolar - Hosur DC @ 85 Deg as given by PGCIL		
4	05-10-2015 to 31-10-2015 to		Operationalization of 530 MW LTA		
5	09-10-2015 to 12-10-2015 to		Due to Vallur Unit -1 Outage Extension		