

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1-S2 for October 2016**

Issue Date: 28/06/2016

Issue Time: 1245 hrs

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st October 2016 to 31st October 2016	00-24	6575	376	6199	3902	2297	0	Revision-0

<b>Limiting Constraint</b>	(n-1) contingency of 400kV Hiriur - Nelamangala D/C
----------------------------	---

**National Load Despatch Centre  
Transfer Capability between S1-S2 for October 2016**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
0	6/24/2016	01-10-2016 to 31-10-2016	Revision-0