

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for September 2015

Issue Date: 29/06/2015

Issue Time: 1300 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2015 to 7th September 2015	00-24	3955	350	3605	2353	1252	390	Revised due to 400kV Mettur - TVLM DC & NTPL Unit - 1 commissioning
8th September 2015 to 14th September 2015	00-24	3955	350	3605	2264	1341	390	
15th September 2015 to 21st September 2015	00-24	3955	350	3605	2341	1264	390	
22nd September 2015 to 25th September 2015	00-24	3955	350	3605	2392	1213	390	
26th September 2015 to 27th September 2015	00-24	3955	350	3605	2471	1134	390	
28th September 2015 to 30th September 2015	00-24	3955	350	3605	2382	1223	390	

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	---

**National Load Despatch Centre
Total Transfer Capability for Septemeber 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	25-05-2015	01-09-2015 to 30-09-2015	Revision-0
1	29-06-2015	01-09-2015 to 30-09-2015	Revised due to 400kV Mettur - TVLM DC & NTPL Unit - 1 commissioning