

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for September 2015

Issue Date: 21/07/2015

Issue Time: 1200 hrs

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2015 to 7th September 2015	00-24	3955	350	3605	2554	1051	0	STOA Margin revised considering CERC order dated 03-07-2015 in petition No-92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.
8th September 2015 to 14th September 2015	00-24	3955	350	3605	2465	1140		
15th September 2015 to 21st September 2015	00-24	3955	350	3605	2542	1063		
22nd September 2015 to 25th September 2015	00-24	3955	350	3605	2593	1012		
26th September 2015 to 27th September 2015	00-24	3955	350	3605	2672	933		
28th September 2015 to 30th September 2015	00-24	3955	350	3605	2583	1022		

Limiting Constraint	(n-1) contingency of 400kV Kolar-Hosur D/C
----------------------------	---

**National Load Despatch Centre
Total Transfer Capability for Septemeber 2015**

Revision No	Date of Revision	Period of Revision	Reason for Revision
0	25-05-2015	01-09-2015 to 30-09-2015	Revision-0
1	26-06-2015	01-09-2015 to 30-09-2015	Revised due to 400kV Mettur - TVLM DC & NTPL Unit - 1 commissioning
2	21-07-2015	01-09-2015 to 30-09-2015	STOA Margin revised considering CERC order dated 03-07-2015 in petition No-92/MP/2015 which is under implementation by CTU. Pending this any margins would be released for short term transactions on day ahead basis.