

Natioanl Load Despatch Centre, New Delhi
Transfer Capability between S1-S2 for September 2016

Issue Date: 26/07/2016

Issue Time: 19:00 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2016 to 13th September 2016	00-24	7443	384	7059	3505	3554	2038	Considering latest LGBR and ISGS outage plan as per 122nd OCCM
14th September 2016 to 24th September 2016					3736	3323		
25th September 2016 to 26th September 2016					3891	3168		
27th September 2016 to 30th September 2016					3659	3400		

Limiting Constraint	(n-1) contingnecy of 400kV Hiriyr - Nelamangala D/C
----------------------------	--