## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for April 2021

Issue Date: 27/04/2021		Issue Time: 15:00 Hrs			Revision No. 6				
Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st April 2021 to 30th April 2021	00 - 24	8400	450	7950	3589	4361	200	Revision-1. Due to commissioning of Kozhikode - Madakathara D/C, Raigarh - Pugalur Pole -2. AWEKL LTA granted to KSEB.	
23rd April 2021	00 - 08	8400	450	7950	3589	4361	200		
23rd April 2021	08 - 24	7700	450	7250	3589	3661	-700	Revision-2. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh- Pugulur HVDC	
24th April 2021	00 - 08	8400	450	7950	3589	4361			
24th April 2021	08 - 24	7700	450	7250	3589	3661	-700	Revision-3. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh- Pugulur HVDC	
25th April 2021	00 - 08	8400	450	7950	3589	4361	0		
25th April 2021	08 - 24	7700	450	7250	3589	3661	-700	Revision-4. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh- Pugulur HVDC	
28th April 2021	00 - 08	8400	450	7950	3589	4361	0		
28th April 2021	08 - 24	7700	450	7250	3589	3661	-700	Revision-5. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh- Pugulur HVDC	
29th April 2021	00 - 08	8400	450	7950	3589	4361	0		
29th April 2021	08 - 24	7700	450	7250	3589	3661	-700	Revision-6. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh- Pugulur HVDC	
30th April 2021	00 - 24	8400	450	7950	3589	4361	0		
one or combination	i. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT								
thereof) Note-1		ii. N-1 violation 2x315 MVA ICT at 400/230kV Thiruvallam ICT S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-1 psi comprises Andura riadesii, relangana and Karnataka and Goa(SK); S2 comprises ramit Nadu and Pondicherry; S5 comprises Kerala									

## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for April 2021

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2021 to 30th April 2021	00-24	3300	90	3210	2799	411		
	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT iii. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to Low Voltage at Palakkad/Trichur							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

## National Load Despatch Centre Transfer Capability between S1- (S2&S3) for April 2021 Transfer Capability between S1- (S2&S3) for April 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	26-12-20	01-04-2021 to 30-04-2021	Revision-0	-
1	31-03-21	01-04-2021 to 30-04-2021	Revision-1. Due to commissioning of Kozhikode - Madakathara D/C, Raigarh - Pugalur Pole -2. AWEKL LTA granted to KSEB.	S1-(S2&S3)
2	22-04-21	23-04-21	Revision-2. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh-Pugulur.	S1-(S2&S3)
3	22-04-21	24-04-21	Revision-3. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh-Pugulur.	S1-(S2&S3)
4	23-04-21	25-04-21	Revision-4. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh-Pugulur.	S1-(S2&S3)
5	26-04-21	28-04-21	Revision-5. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh-Pugulur.	S1-(S2&S3)
6	27-04-21	29-04-21	Revision-6. Due to pole-2 outage of 800kV Raigarh- Pugulur HVDC for the testing of pole-4 of 800kV Raigarh-Pugulur.	S1-(S2&S3)