

**Natioanl Load Despatch Centre, New Delhi**  
**Transfer Capability between S1- (S2&S3) for April 2022**

Issue Date: 22/04/2022

Issue Time: 1100 Hrs

Revision No. 10

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 2nd April 2022	00 - 24	8600	450	8150	4084	4066		
3rd April 2022 to 09th April 2022	00 - 24	8600	450	8150	4224	3926		
10th April 2022 to 21st April 2022	00 - 24	8600	450	8150	4445	3705		
22nd April 2022 to 30th April 2022	00 - 24	8600	450	8150	4241	3909		
Limiting Constraints (any one or combination thereof)	i. N-1 violation 2x315 MVA ICTs at 400/230kV Thiruvallam SS							
	ii. N-1 violation of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur ICT							
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
	iv. N-1 violation 2x250 MVA ICTs at 400/230kV Neyveli Stage2							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**Natioanl Load Despatch Centre, New Delhi**  
**Import Capability of S3 for April 2022**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st April 2022 to 2nd April 2022	00-24	3300	90	3210	2692	518		
3rd April 2022 to 9th April 2022	00-24	3300	90	3210	2637	573		
10th April 2022	00-09	3300	90	3210	2637	573		
	09-24	3000	90	2910	2637	273		
11th April 2022 to 13th April 2022	00-24	3300	90	3210	2637	573		
14th April 2022	00 - 09	3300	90	3210	2637	573		
	09 - 24	2800	90	2710	2637	73		
15th April 2022	00 - 09	3300	90	3210	2637	573		
	09 - 24	2800	90	2710	2637	73		
16th April 2022	00 - 09	3300	90	3210	2637	573		
	09 - 24	2800	90	2710	2637	73		
17th April 2022	00 - 09	3300	90	3210	2637	573		
	09 - 24	3300	90	3210	2637	573		
18th April 2022 to 21st April 2022	00-24	3300	90	3210	2637	573		
22nd April 2022	00-09	3300	90	3210	2637	573		
	09-24	2950	90	2860	2637	223		
23rd April 2022	00-24	3300	90	3210	2637	573		
	00-09	3300	90	3210	2637	573		
24th April 2022	00-09	3300	90	3210	2637	573		
	09-24	2950	90	2860	2637	223	-350	Revision - 10 : Due to shutdown of 400kV/220kV Madakathara ICT-3
25th April 2022 to 30th April 2022	00-24	3300	90	3210	2637	573		
Limiting Constraint (any one or	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT							
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Cochin will lead to over-loading of the Other ICT							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

**National Load Despatch Centre**  
**Transfer Capability between S1- (S2&S3) for April 2022**  
**Import Capability of S3 for April 2022**

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor	Quantum of MW revised
0	26-12-2021	01-04-2022 to 30-04-2022	Revision-0	-	
1	30-03-2022	01-04-2022 to 30-04-2022	1.Revised LGBR 2.Latest network		
2	01-04-2022	03-04-2022 to 30-04-2022	140.4 MW Share allocated to Tamil Nadu from NTPC Bongaingaon (NER)	S1- (S2&S3)	
3	08-04-2022	10-04-2022	Revision - 03 : Due to shutdown of 400kV/220kV Madakkathara ICT-2	Import of S3	-350
4	09-04-2022	10-04-2022 to 30-04-2022	Revision - 04 : Due to revised share allocation to Tamil Nadu from Barh1,Barh-2 and FSTPP-3	S1- (S2&S3)	
5	12-04-2022	14-04-2022	Revision - 05 : Due to shutdown of 400kV/220kV Trivendrum ICT-1	Import of S3	-500
6	13-04-2022	15-04-2022	Revision - 06 : Due to shutdown of 400kV/220kV Trivendrum ICT-2	Import of S3	-500
7	14-04-2022	16-04-2022	Revision - 07 : Due to shutdown of 400kV/220kV Trivendrum ICT-3	Import of S3	-500
8	15-04-2022	17-04-2022	Revision - 08 : Due to shutdown of 400kV/220kV Madakathara ICT-1	Import of S3	-350
9	20-04-2022	22-04-2022	Revision - 09 : Due to shutdown of 400kV/220kV Madakathara ICT-3	Import of S3	-350
10	22-04-2022	24-04-2022	Revision - 10 : Due to shutdown of 400kV/220kV Madakathara ICT-3	Import of S3	-350