

National Load Despatch Centre, New Delhi
Transfer Capability between S1- (S2&S3) for April 2024

Issue Date: 28-11-2023

Issue Time: 1700 Hrs

Revision No. 0

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA S1- (S2&S3) (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision
1 st to 30th April 2024	00 -24Hrs	1-96	10000	450	9550	5574	3976	
Limiting Constraints (any one or combination thereof)	i. Tripping of 500 MVA ICT will lead to overloading of 2x315 MVA ICT at 400/230kV Allundur SS							
	ii. N-1 violation 2x315 MVA ICTs at 400/230kV Tiruvallam SS							
	iii. N-1 violation 2x500 MVA ICTs at 400/230kV NNTPP							
	iv. N-1 violation 2x250 MVA ICT at 400/230kV NEYVELI Stage2							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							

National Load Despatch Centre, New Delhi
Import Capability of S3 for April 2024

Issue Date: 28-11-2023

Issue Time: 1700 Hrs

Revision No. 0

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	Approved GNA (MW)	Margin for T-GNA (MW)	Changes in TTC w.r.t last revision	Remarks
1 st to 30th April 2024	00-24	1-96	3950	90	3860	2679	1181		
Limiting Constraint (any one or combination thereof)	i. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Palakkad will lead to over-loading of the Other ICT								
	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT								
	iii. (n-1) contingency of one ICT of (2x315 MVA +1x500 MVA) 400/220kV ICT at Kozhikode SS will lead to over-loading of the Other ICT								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

