Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for April 2025

Issue Date: 21/03/2025 Issue Time: 1800 Hrs Revision No. 1

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	NET GNA S1- (S2&S3) (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision (MW)	Remarks
1st to 30th Apr 2025	00 -24Hrs	1-96	10900	450	10450	5574	4876	400	R1
(any one or combination	in. Tripping of 100k (11011 b Manan b) C will cause overloading of 100k (Manan b) C								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								

Natioanl Load Despatch Centre, New Delhi Import Capability of S3 for April 2025

Date	Time Period	Time Blocks	Total Transfer Capability (TTC) (MW)	Reliability Margin (RM) (MW)	Available Transfer Capability (ATC) (MW)	Approved GNA (MW)	Margin for T- GNA (MW)	Changes in TTC w.r.t last revision	Remarks	
1st to 30th Apr 2025	00-24	1-96	4575	120	4455	2679	1776	225	R1	
	i. (n-1) contingency of one ICT of (2x315 MVA +1x500 MVA) 400/220kV ICT at Kozhikode SS will lead to over-loading of the Other ICT									
combination dicteor)	ii. (n-1) contingency of one ICT of (2x315 MVA) 400/220kV ICT at Trichur HVDC will lead to over-loading of the Other ICT									
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala									

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for April 2025 Import Capability of S3 for April 2025

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	25-04-2024	01-04-2025 to 30-04-2025	Revision-0	-
1	21-03-2025	01-04-2025 to 30-04-2025	Revision-1 Revision-1	S1-(S2&S3) S3 Import