Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for August 2019

Issue Date: 28th April 2019 Issue Time: 1600 Hrs Revision No. 0

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st August 2019 to 31st August 2019	00 - 24	8600	490	8110	3563	4547			
	i. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS								
Limiting Constraints	ii. (n-1) contingency of one circuit of 400 kV Hosur - Salem will lead to overloading of the other circuit								
(any one or	iii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit								
combination thereof)	iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit								
	v. Low Voltage in Kerala (S3)								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and								
Note-2	System Protection Shcheme (SPS)								

Natioanl Load Despatch Centre, New Delhi Transfer Capability for Import of S3 for August 2019

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2019 to 31st August 2019	00-24	2930	90	2840	2738	102		
one or	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit * ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

National Load Despatch Centre Transfer Capability between S1- (S2&S3) for August 2019 Transfer Capability for Import of S3 for August 2019

R	Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
	0	26th April 2019	Whole Month	Revision-0	-